

Report on Results of 2003 & 2004 Presentations of VRLA “Boosted” Batteries and Remote Battery Monitoring Respectively

Infobatt2005 – Toronto
October 2-4 2005

Robert Szasz, P.Eng. – MTS Allstream Corp



Contents

- Overview
- VRLA “Boosted” Batteries
- Summary of 2003 Presentation
- Results of 4th year in service
- Conclusions
- Battery Remote Monitoring
- Summary of 2004 Presentation
- Results of 1st year
- Phase 2 evaluation
- Conclusions



Overview

The objective of this paper is to provide update on progress of previous years Infobatt presentations.

- VRLA “Boosted” Batteries results of 4th year in service
- Battery Remote Monitoring and Control – results of first year in service.

It is believed that this report of results from a major operator will be beneficial to the industry, vendors, consultants and 2005 Infobatt participants.

VRLA Booster Batteries

Summary of 2003 Presentation

- Old battery stock with (4) years shelf life was acquired during company merger and originally considered to be scrap.
- Batteries of 1997 vintage have been boosted through a combination of constant voltage and current charge/discharge (C&D) or constant voltage only charge/discharge (GNB)
- Batteries have been installed in 2001 and are in use at over 20 MTS Allstream sites.

Summary of 2003 Presentation (continued)

Battery Stock Acquired



Battery Stock Acquired

Manufacturer	Model/ Type	Number of Strings
C&D Tech.	HD-300	20
C&D Tech.	HD-700	6
C&D Tech.	HD-1100	3
GNB Power.	90A-07	11



Over \$340,000 in new equipment value

Summary of 2003 Presentation (continued)

- The batteries were regularly monitored to ensure they are serving sufficiently. At the time of 2003 presentation the batteries have been in service for app 24 months and were performing well.
- All batteries have performed well during Ontario blackout of August 14, 2003. None of these battery failed during the duration of the blackout.

Battery Installation Sites

Number of Strings	Location	Site Installation Date
2 x HD300	Alexandria	April/01
2 x HD300	Mirabell TC	June/01
2 x HD300	ST. Therese TC	June/01
2 x HD300	Pont Viau TC	June/01
2 x HD300	Cobourg TC	Aug/01
2 x HD300	Concord TC	Aug/01
2 x HD300	Joilette	Aug/01
2 x HD300	Jonquiere	Aug/01
2 x HD300	Coteau	Aug/01
1 x HD300	Welland	Sept-Oct 2001
1 x HD300	Woodstock	Sept-Oct 2001

Number of Strings	Location	Site Installation Date
2 x HD700	Tweed	April/01
2 x HD700	Tichborne	April/01
2 x HD700	Dorion	April/01

Number of Strings	Location	Site Installation Date
1 x HD1100	Wolfdale	May/01
1 x HD1100	Guelph	May/01
1 x HD1100	C&D	Undetermined

Number of Strings	Location	Site Installation Date
1 X 90A-07	438 U -Lab	May/01
3 X 90A-07	5160 Orbitor	June/01
1 X 90A-07	Metro Centre	July/01
1 X 90A-07	Mississauga Dixie/Eglinton	July/01
2 X 90A-07	Glencoe	July/01
2 X 90A-07	Gracie	July/01
1 X 90A-07	GNB Facilities	Undetermined



Results of 4th year in service (7-8th from manufacturing)

- The intent of this report is to :
- present results of 4th year in service of boosted batteries (7-8 years from year of Manufacture)
- compare with results of batteries which have been charged and/or installed within the 6 months period recommended by Manufacturer.
- Criteria for evaluation of the state of health of the batteries was the conductance measurements with Midtronics Celltron meters.

Results of 4th year in service (7-8th from manufacturing) cont..

- Overall results indicate that conductance was maintained within 80-100% at most of the sites.
- C&D visited (8) sites between April-June 2005 with following results :
- Battery re-hydration procedure has been applied at all sites –conductance readings after the procedure of adding water were 100-120%
- One cell each at (2) sites did not pass the pressure test performed before re-hydration-cells were replaced at later date.

Example of Boosted Batteries (1)

Allstream Alexandria fots Plant #1					Allstream Alexandria Fots Plant #1				
JAR	R - Volts	Jar -- G	% Ref.		JAR	R - Volts	Jar -- G	% Ref.	
001	2.22	1668	92%		001	2.22	2045	113%	
002	2.24	1427	79%		002	2.24	2063	114%	
003	2.24	2010	111%		003	2.24	1993	110%	
004	2.22	1456	80%		004	2.22	2112	117%	
005	2.2	1569	87%		005	2.2	1956	108%	
006	2.2	1439	79%		006	2.2	1943	107%	
007	2.22	1595	88%		007	2.22	1992	110%	
008	2.2	1923	106%		008	2.2	1862	103%	
009	2.24	1512	84%		009	2.24	2110	111%	
010	2.22	1856	103%		010	2.22	2120	117%	
011	2.2	1574	87%		011	2.2	1793	99%	
012	2.22	1501	83%		012	2.22	1962	109%	
013	2.22	1308	72%		013	2.22	2063	114%	
014	2.22	1850	102%		014	2.22	2052	114%	
015	2.24	1938	110%		015	2.24	2144	119%	
016	2.2	2017	112%		016	2.2	1945	108%	
017	2.24	1640	91%		017	2.24	2160	120%	
018	2.22	1501	83%		018	2.22	1838	102%	
019	2.25	1379	76%		019	2.25	1936	107%	
020	2.22	1880	104%		020	2.22	2100	116%	
021	2.2	1875	104%		021	2.2	2169	120%	
022	2.22	1516	84%		022	2.22	1930	107%	
023	2.22	1943	107%		023	2.22	1960	93%	
024	2.22	1478	82%		024	2.22	1949	108%	
Reference Value Entered: 1800 Siemens (MHOS)					Reference Value Entered: 1800 Siemens (MHOS)				
Liberty 2000MAX, type HD-300					Liberty 2000MAX, type HD-300				
Reference Temperature: 21 Degrees Celsius					Reference Temperature: 21 Degrees Celsius				
String Average: 1662s					String Average: 1992s				
String % of Ref: 92%					String % of Ref: 110%				
Manufacture Date: 1997/04					Manufacture Date: 1997/04				
Test performed BEFORE_ the procedure of adding H2O					Test performed AFTER_ the procedure of adding H2O				

Example of Boosted Batteries (2)

Allstream Alexandria fots Plant #2					Allstream Alexandria Fots Plant #2				
	JAR	R - Volts	Jar -- G	% Ref.		JAR	R - Volts	Jar -- G	% Ref.
	001	2.24	1936	107%		001	2.24	1983	110%
	002	2.2	1424	79%		002	2.2	2201	122%
	003	2.25	2218	123%		003	2.25	2176	120%
	004	2.22	2096	116%		004	2.22	2128	118%
	005	2.22	1996	110%		005	2.22	2082	115%
	006	2.2	1497	83%		006	2.2	2045	113%
	007	2.22	2075	115%		007	2.22	2071	115%
	008	2.24	1776	98%		008	2.24	2297	127%
	009	2.25	2390	132%		009	2.25	2188	121%
	010	2 20	1297	72%		010	2 20	2278	126%
	011	2.2	1655	91%		011	2.2	2096	115%
	012	2.25	2222	123%		012	2.25	2297	127%
	013	2.22	2112	117%		013	2.22	2120	117%
	014	2.2	1493	82%		014	2.2	2169	120%
	015	2.2	2085	115%		015	2.2	2013	111%
	016	2.2	1504	83%		016	2.2	1804	100%
	017	2.24	1971	109%		017	2.24	1816	100%
	018	2.17	1640	91%		018	2.17	1640	93%
	019	2.22	1338	74%		019	2.22	2119	117%
	020	2.25	2230	123%		020	2.25	2297	127%
	021	2.24	1396	77%		021	2.24	2196	122%
	022	2.22	2172	120%		022	2.22	2117	120%
	023	2.22	1976	109%		023	2.22	1996	110%
	024	2.22	1911	106%		024	2.22	1868	103%
Reference Value Entered: 1800 Siemens (MHOS) Liberty 2000MAX, type HD-300 Reference Temperature: 21 Degrees Celsius					Reference Value Entered: 1800 Siemens (MHOS) Liberty 2000MAX, type HD-300 Reference Temperature: 21 Degrees Celsius				
String Average: 1850s String % of Ref: 102% Manufacture Date: 1997/04					String Average: 2087s String % of Ref: 115% Manufacture Date: 1997/04				
Test performed BEFORE_ the procedure of adding H2O					Test performed AFTER_ the procedure of adding H2O				
Cell # 18 fails presure test. No H2O added to this cell.									

Example of Same Vintage Batteries 1 (not boosted)

Allstream Smith Falls Plant #1				Allstream Smith Falls Plant #1			
JAR	R - Volts	Jar -- G	% Ref.	JAR	R - Volts	Jar -- G	% Ref.
001	2.22	1466	60%	001	2.22	2949	121%
002	2.22	1604	66%	002	2.2	2952	122%
003	2.22	1320	53%	003	2.2	2876	119%
004	2.22	1268	51%	004	2.2	2740	112%
005	2.24	1354	55%	005	2.22	2478	102%
006	2.24	1646	67%	006	2.24	2813	115%
007	2.22	1434	58%	007	2.2	2892	119%
008	2.22	1010	41%	008	2.22	2779	114%
009	2.22	1569	64%	009	2.24	2879	119%
010	2.22	1475	61%	010	2.20	2957	112%
011	2.22	1431	58%	011	2.22	2690	110%
012	2.24	996	40%	012	2.22	2635	108%
013	2.24	1158	47%	013	2.24	2691	110%
014	2.22	1400	57%	014	2.22	2816	115%
015	2.22	1541	63%	015	2.22	2922	120%
016	2.25	1622	66%	016	2.28	2974	122%
017	2.22	1282	52%	017	2.22	2722	111%
018	2.22	1583	65%	018	2.22	2982	123%
019	2.22	1302	53%	019	2.22	2857	117%
020	2.24	1407	57%	020	2.22	2774	113%
021	2.24	1311	53%	021	2.22	2767	113%
022	2.24	1367	55%	022	2.24	2936	121%
023	2.24	1675	69%	023	2.24	2944	121%
024	2.25	1509	62%	024	2.27	2949	121%
Reference Value Entered: 2500 Siemens (MHOS)				Reference Value Entered: 2500 Siemens (MHOS)			
Liberty 2000MAX, type HD-500				Liberty 2000MAX, type HD-500			
Reference Temperature: 21 Degrees Celsius				Reference Temperature: 21 Degrees Celsius			
String Average: 1405s				String Average: 2832s			
String % of Ref: 57%				String % of Ref: 116%			
Manufacture Date: 1998/04				Manufacture Date: 1998/04			
Test performed BEFORE _ the procedure of adding H2O				Test performed AFTER _ the procedure of adding H2O			

Example of Batteries (2)

<u>Allstream Smith Falls Plant #2</u>					<u>Allstream Smith Falls Plant #2</u>				
	JAR	R - Volts	Jar -- G	% Ref.		JAR	R - Volts	Jar -- G	% Ref.
	001	2.24	1729	69%		001	2.24	3051	122%
	002	2.22	1757	70%		002	2.22	2892	116%
	003	2.22	1725	69%		003	2.22	2966	119%
	004	2.22	2020	81%		004	2.22	2959	118%
	005	2.22	1911	76%		005	2.22	2944	118%
	006	2.22	1610	64%		006	2.24	2952	118%
	007	2.24	1431	57%		007	2.24	2678	107%
	008	2.25	1873	75%		008	2.27	3038	122%
	009	2.22	1894	76%		009	2.22	3013	121%
	010	2.22	1614	65%		010	2.22	2944	118%
	011	2.22	1730	69%		011	2.19	2974	119%
	012	2.22	1906	76%		012	2.2	2697	108%
	013	2.22	1858	74%		013	2.24	2774	111%
	014	2.22	1545	62%		014	2.24	2929	117%
	015	2.22	1846	74%		015	2.22	3091	124%
	016	2.24	1858	74%		016	2.25	3101	124%
	017	2.22	1985	79%		017	2.22	3093	124%
	018	2.22	1725	69%		018	2.22	3028	121%
	019	2.22	1665	67%		019	2.22	2936	117%
	020	2.22	1864	75%		020	2.22	2927	117%
	021	2.22	1750	70%		021	2.24	3013	121%
	022	2.22	1478	59%		022	2.22	2959	118%
	023	2.24	1894	76%		023	2.24	3150	126%
	024	2.22	1528	61%		024	2.22	2829	113%
Reference Value Entered: 2500 Siemens (MHOS)					Reference Value Entered: 2500 Siemens (MHOS)				
Liberty 2000MAX, type HD-500					Liberty 2000MAX, type HD-500				
Reference Temperature: 21 Degrees Celsius					Reference Temperature: 21 Degrees Celsius				
String Average: 1758s					String Average: 2956s				
String % of Ref: 70%					String % of Ref: 118%				
Manufacture Date: 1998/04					Manufacture Date: 1998/04				
Test performed BEFORE _ the procedure of adding H2O					Test performed AFTER _ the procedure of adding H2O				

Smith Falls tower



Smith Falls Batteries



4th year results (cont)

- Boosted GNB batteries conductance readings continue to be over 80% with no re-hydration procedure
- Several GNB batteries strings of same vintage have been either re-hydrated or have been replaced.

■ **Conclusions**

- Fourth year results indicate that these batteries are performing as well or even better when compared with similar batteries in our network which have been charged and/or installed within recommended 6 months period.
- Present signs show batteries are serving well and are expected to be in service for at least another 2-3 years.

Remote Battery Monitoring Summary of 2004 presentation

- MTS Allstream selected in 2004 a DC Power Plant with Remote Battery Monitoring capabilities
- The benefits of this system or similar can be summed up as follows:
 - Routine remote battery monitoring and control reduces the frequency of man-hour routines in the field and will all but eliminate system outages caused by failed batteries
 - Programmable alarms for current, voltage, temperature and battery capacity provides back-up for existing alarm system
 - Historical data logs are valuable tool in the investigation of system outages and product performance.

Summary of 2004 Presentation (cont)

- The increased visibility to the battery plant can allow for more effective deployment of mobile generators in the event of large-scale power outages and thus enhance the survivability of the network. Mobile generators can be dispatched to locations based on network priorities and the remaining battery reserve based on real time data.

The system capabilities and actual man-hour results for the sites implemented will be reviewed after one year to confirm the savings and benefits prior to any further rollouts.

Summary of 2004 Presentation (cont)

Network connectivity

The following are Allstream key requirements :

- TCP/IP Ethernet connection between the remote DC power plants and host computers (Dial-up connectivity not accepted due to security concerns - allowed for the trial on the first two sites only)
- SNMP capabilities at a later phase of the project once significant number of sites will be added

Project Challenges

- Installation of these systems required establishment of new Network OSS infrastructure connectivity system
- The least cost of such systems is an added cost of approximately 60% of the costs of selected DC power plants

Network Connectivity (continued)


- There are a number of remote sites at which the connectivity costs are very high and therefore it renders impractical the use of remote capabilities.
- All sites have been equipped with RT5 rectifiers and MiniCSU controllers supplied by Spectral.
- Each site has been equipped with a Cisco 2610 router to allow remote connectivity to the MTS Allstream OSS network.

Network Connectivity (continued)

- The site routers connect via an Ethernet port to the telemetry MiniCSU rectifier controller. The site routers are connected via DS1/56kbs transport to appropriate homing locations in each region.
- The following is a typical connectivity diagram implemented for phase 2 of this evaluation.

Attachments

Typical Rectifier System Configuration



Phase 2-Field evaluation summary

- Phase 1 - started Q1 2003 -Vendor and technology selection complete with 12 -16 months field trial-satisfactory results obtained
- Phase 2- design and implementation of several systems for further evaluation completed Q1 2005
- **Project Implementation challenges**
 - The challenges continued to be in respect to OSS LAN/Network connectivity , 7/24 monitoring capabilities and conductance measurements.
 - **OSS LAN Issue** : Data Technology group do not recommend the rectifiers to be connected to the OSS net without a dedicated Authentication Server – Rectifiers are temporarily connected to the OSS net

Phase 2-Field evaluation summary

- Dedicated PC will be required until authentication server will be installed later this year.
- **Network connectivity challenges:**
- Remote communication has been established at (7) out of the (10) sites only.
- At the time of writing this paper Network Engineering is still investigating cost effective solutions to implement remote communication to the balance of (3) sites
- **Field Operation challenges :**
- Lack of manpower and commitment for 7/24 Remote Monitoring of the system renders the system less attractive

Phase 2-Field evaluation summary

- Field Operation personnel still have to travel to remote sites to perform quarterly conductance measurements as the selected system does not have such remote capabilities.